

TOWN OF RICHMOND
Town Board Resolution
02 2018 xx

Resolution of SEQR Type II Action - Allens Hill Culvert Replacement

RESOLVED, that in accordance with the New York State Environmental Quality Review (SEQR) procedures, the Town Board of the Town of Richmond has reviewed the significance of and potential environmental impact of the replacement of the existing 60" Corrugated Metal Culvert Pipe with 90 linear feet of Smooth Interior Corrugated Polyethylene Pipe.

RESOLVED, that the Town Board hereby concurs with Chatfield Engineers, P.C. that the Project is considered a Type II Action in accordance with 6NYCRR Part 617.5 (c){2}; a replacement, rehabilitation or reconstruction of a structure or facility, in kind, on the same site

RESOLVED, that the Town Board hereby accepts the Environmental Assessment of this project, prepared by Chatfield Engineers, P.C.. The Town Board further declares that, based on the Environmental Assessment, it finds that the projects will result in no significant adverse impacts to the environment and requires no further action.